

Item	QTY	Symbol	Description	Mfg. & Part Number
1	1		Enclosure, 30 X 30 X 12, SS, NEMA 4X	Saginaw #SCE-30EL3012SS6LP
2	1		Sub-Panel	Saginaw #SCE-30P30
3	1		Dead Front Panel	Saginaw #SCE-DF30EL30LP
4	1		Mounting Foot Kit	Saginaw #SCE-ELMFK4SS
5	1	109HMI	PanelView Plus 6 700	Allen-Bradley #2711P-T7C4A8
6	1	107SPD	Surge Suppressor	Edco #HSP121BT-1RU
7	3	137LT, 147LT, 214LT	Pilot Light, Red LED, Push-to Test	Allen-Bradley #800H-QRTH10R
8	5	117LT, 126LT, 139LT, 149LT, 212LT	Pilot Light, Green LED, Push-to Test	Allen-Bradley #800H-QRTH10G
9	4	118LT, 127LT, 150LT, 151LT	Pilot Light, Amber LED, Push-to Test	Allen-Bradley #800H-QRTH10A
10	5	111PB, 120PB, 133PB, 143PB, 205PB	Pushbutton, Green Flush Head	Allen-Bradley #800H-AR1A
11	5	110PB, 119PB, 132PB, 142PB, 204PB	Pushbutton, Red Flush Head	Allen-Bradley #800H-AR6A
12	1	204SS	Selector Switch, 2-Position	Allen-Bradley #800H-HR2B
13	23		Legend Plate, NEMA 4X (engraved as shown)	Allen-Bradley #800H-W500J
14	1	104TAS	Thermostat	Saginaw #SCE-TEMNO
15	1	1CB	Circuit Breaker, 15 AMP	AutomationDirect #WMZT1C15
16	21	All CR's	Relay, 2PDT	Idec #RH2B-ULCAC110-120V
17	21	(for above)	Relay Socket	Idec #SH2B-05
18	116		Terminal Block	Allen-Bradley #1492-J4
19	4		Terminal Block End Barrier	Allen-Bradley #1492-EBJ3
20	11		Terminal Block End Anchor	Allen-Bradley #1492-ERL35
21	2		Terminal Block, Grounding	Allen-Bradley #1492-JG4
22	A/R		DIN Rail, 35mm	Allen-Bradley #199-DR1
23	A/R		DIN Rail, 35mm, Raised	AutomationDirect #DN-R35SAL2-2
24	1		Ground Lug	Blackburn #L35 (or equal)
25	A/R		Wireway with Cover, 1" X 3"	Panduit (or equal)
26	1	1FAN	Fan Heater with Thermostat, 200 Watt	Saginaw #SCE-HF2001A
27	1	2CB	Circuit Breaker, 3 AMP	AutomationDirect #WMZT1C03
28	A/R	1CA	Shielded Cable, #24 AWG, 9-Conductor	Belden #9934 (or equal)
29	1		Connector, DB-9, Female	Purchase
30				

THIS DRAWING CONTAINS INFORMATION PROPRIETARY TO APEX AUTOMATION AND CONTROLS. IT IS SUBMITTED IN CONFIDENCE AND IS TO BE USED SOLELY FOR THE PURPOSE FOR WHICH IT IS FURNISHED AND RETURNED UPON REQUEST. THIS DRAWING AND SUCH INFORMATION IS NOT TO BE REPRODUCED, TRANSMITTED, DISCLOSED, OR USED OTHERWISE IN WHOLE OR IN PART WITHOUT THE WRITTEN AUTHORIZATION OF APEX AUTOMATION AND CONTROLS.

REV	REVISION DESCRIPTION	DRAWN	CHECKED	APP	DATE
0	ORIGINAL ISSUE	ADH			10/9/2014
A	REVISED PER CUSTOMERS COMMENTS	ADH			10/21/2014

REV	REVISION DESCRIPTION	DRAWN	CHECKED	APP	DATE



Apex Automation & Controls
10991 Leadbetter Road Ashland, VA 23005
(804) - 550 - 1814
www.apex-automation.com

DRAWN	BY	DATE
ADH	ADH	10/9/14
CHECKED		
APP		
SCALE	N/A	

WESTERN VIRGINIA WATER AUTHORITY			
CARVINS COVE WTF CHEMICAL BUILDING 2			
SODIUM HYPOCHLORITE CONTROL PANEL			
MATERIALS LIST			
175-14-200	1 of 1	A	