

BOXLEY HILLS TONE MODULE

LOCATION 1	LOCATION 2	LOCATION 3	LOCATION 4
MS 20	FREQUENCY 2000	FREQUENCY 1575	FREQUENCY 1775
POWER SUPPLY	MR55C RECEIVER	MT5 TRANSMITTER	MT55 TRANSMITTER
	PUMP CONTROL	PUMP STATUS	LINE VALVE STATUS
LOCATION 5	LOCATION 6	LOCATION 7	LOCATION 8
FREQUENCY 1175			
MT5 TRANSMITTER			
DISCHARGE PRESSURE			

CARVINS COVE TONE MODULE

LOCATION 1	LOCATION 2	LOCATION 3	LOCATION 4
MS 20	FREQUENCY 1075	FREQUENCY 1175	FREQUENCY 1375
POWER SUPPLY	MR5 RECEIVER	MR5 RECEIVER	MR5 RECEIVER
	CITY FARM LEVEL	DISCHARGE PRESSURE	INDUSTRIAL PARK
LOCATION 5	LOCATION 6	LOCATION 7	LOCATION 8
	FREQUENCY 2000	FREQUENCY 1575	FREQUENCY 1775
	MT55C TRANSMITTER	MR5 RECEIVER	MR55C RECEIVER
	PUMP CONTROL	PUMP STATUS	LINE VALVE STATUS
LOCATION 9	LOCATION 10	LOCATION 11	LOCATION 12