




COMMONWEALTH OF VIRGINIA
ARCHITECT
WILLIAM L. TOWNSEN
NO. 4277

DRAWN
BY
CHECKED
DATE 3-10-80
SCALE
NOTES
JOB NO.
2-110
SHEET
2
OF 2 SHEET



14 = 16



SEE FLOOR PLAN FOR DIMENSIONS

1. LAVATORY: AMERICAN STANDARD D430, OT, WHITE, 8" x 6" FAUCET HOLES; FAUCET: AAV STD 2000, 101 IN AERATOR POP-UP DRAIN, ALL EXPOSED PIPING & FAUCETS - CHROME PLATED.
2. URINAL: WALL MTD. LYNBROOK 1-0; 6601, OT, WHITE, FLOAT TYPAL 100" FLUSH VALVE.
3. WATER CLOSET: AMERICAN STANDARD 2108, 400, WHITE, ELONGATED POWL, H.C. HEIGHT, WHITE SEAT, COVER FOR ELONGATED POWL, CHROME SUPPLY & STOP.
4. WALL HUNG LAVATORY: RE-USE EXISTING.
5. WATER CLOSET: AMERICAN STANDARD 2292, 100, WHITE, WHITE SEAT, COVER, CHROME SUPPLY & STOP, EXISTING ANALYSE RE INSTALLER.
6. FLOOR DRAIN 4" CAST BRASS, FLAT STRAINER, CHROME PLATED.
7. WATER HEATER: A.O. SMITH ELE. 2 1/2 GA. 12.5 A, 120 V MODEL. 6LC-2-100 OR APPROVED EQUAL, LOCATE HIGH ON WALL IN JACUETTE ROOM.

1 SURFACE MOUNTED 2x4 4-LAMP FLUORESCENT FIXTURE'S, ACRYLIC LENS'S, WHITE METAL FORMED LAMP BODY, FIXTURES TO BE SUSPENDED FROM STRUCTURE ABOVE @ ± 22 AFF.

2 2x4 RECESSED FLUORESCENT FIXTURE W/ACOUSTIC CEILING, (4) 40W LAMPS, WHITE FORMED STEEL BODY, ACRYLIC LENS'S, 2 LEVEL LIGHTING, WILLIAMS 50 G-524-4250 C-SWLA 125, OR EQUAL.

3 2x4 RECESSED FLUORESCENT FIXTURE IN ACOUSTIC CEILING, (2) 40W LAMPS, WHITE FORMED STEEL BODY, ACRYLIC LENS'S, WILLIAMS 50 G-524-2320 C-SWLA 125 OR EQUAL.

FIGURE 3 & FIGURE 4: WIRED FOR 24 HOUR OPERATION.

4 2x2 RECESSED FLUORESCENT FIXTURE, ACRYLIC LENS'S, (WHITE FORMED) STEEL BODY, (2) 40W LAMPS, MATCH EXISTING 2x2' FIXTURE'S.

5 SELF DIMMER EXIT FIXTURE, CEILING MTD, UNLESS NOTED OTHERWISE, DEF OR GIVEN LETTERS & ARROWS WHERE INDICATED, W/ BACK-UP BATTERY BACK-UP OPERATION, 90 MINUTE RESERVE. HIGH LITES, BPS FLED-5, LND

6 WALL MOUNTED EMERGENCY FIXTURE W/ TWO HEADS, BATTERY BACK-UP W/ "90 MINUTE RESERVE, MOUNT NORMAL 2" BELOW CEILING. HI-LITES HL-80, 6 VOLT 10 WATTS.

7 SURFACE MOUNTED, (4) 60W LAMPS, EXTRUDED ALUM. BODY, PRESCOTT'S 5340-4, OR EQUAL. VERTICAL MOUNTING UNLESS NOTED "H."

8 DUPLEX CONVENIENCE OUTLET, 120 V, 100% PLATE & WIRING, DEVICE ± 24 " AFF.

9 COMPUTER OUTLET, E.C. TO PROVIDE IN-WALL BOX W/ 1/2" CONDUIT FROM BOX TO MINIMUM 12" ARV. CEILING, COMPUTER SYSTEM BY OWNER.

10 TELEPHONE OUTLET, E.C. TO PROVIDE J-BOX W/ 3/4" CONDUIT FROM BOX TO MINIMUM 12" ARV. CEILING, COMPUTER SYSTEM PURCHASED & INSTALLED BY OWNER.

11 LOCAL SWITCH, 120V, 100% PLATE & DEVICE.

12 SMOKE DETECTOR, MATCH EXISTING DEVICES.

13 CEILING FAN(S) CONNECT TO DUCT WORK TO EXISTING TOILET ROOMS EXHAUST SYSTEM, CONSTRAINT 24 HR OPERATION.

14 PIESCOLITE 4041, (2) 100W, 10" SQ. X 18" DEEP, BLACK TRIM, WALL MTD @ $\pm 6'-8"$ AFF.