

SPECIFICATIONS

Contract C

Crystal Spring Booster Station Construction

Bids Called for 2:00 P. M., EST, August 20, 1951

Contract C Specifications Page C-25 refer to cold water line to a sink on main floor, but plans show no sink.

The Contractor shall furnish and install complete with drain, a two-faucet, enameled, cast iron, wall-mounted sink approximately 16 inches by 24 inches by 6 inches with an 8 inch back and rolled rim. One faucet will be ~~for hot water from a future heater.~~ The sink shall be located on the main floor on the wall opposite the drinking fountain in the entrance vestibule. Connect drain to 6 inch cast iron sanitary drain.

CITY OF ROANOKE WATER DEPT.

By: Chas. E. Moore
Engineer in Charge
of Construction