

LOCATION

CRYSTAL SPRING BOOSTER STATION
2006 Jefferson Street, S. W.

UNIT NO.	PUMP NO. 1	PUMP NO. 2	PUMP NO. 3
Make	Delaval 2 stage	Delaval 2 stage	Delaval 2 stage
G.P.M.	700	700	700
Serial No.	256281	256280	256279
Size	5"-S x 4"-D	5"-S x 4"-D	5"-S x 4"-D
Suct. Pres.	85 lbs.	85 lbs.	85 lbs.
Disc. Pres.	175 lbs.	175 lbs.	175 lbs.
T.D.H.	235'	235'	235'
Storage	Res.	Res.	Res.
Make Motor	G.E.	G.E.	G.E.
Serial No.	WH6956379	UH6928626	UH6928627
H.P.	60	60	60
Voltage	440	440	440
Amp. F.L.	73	73	73
Amp. Fuse			
Phase	3	3	3
R.P.M.	1765	1765	1765
Control	Automatic	Automatic	Automatic
In-C Line	Underground		
Elev. Pump	947 Approx.	Approx. 947'	
Max.Elev.Serv.			
Storage Elev.			
Purchased	1951	1951	1951

CONTROLS-NAME-KIND-TYPE	SERIAL NO.	VOLTS	AMPS	FUSE	CAP.	PHASE	
Autocon Type "Spec."	22711	110	3W		300		
Westinghouse Volt Meter	NP28080-E						
Recording Duragauge Pressure	15662	110					
Builders Propeloflo meter "12"PRF	6PBY-1560				2400 GPM		
" Model Per-Tir Transmitter &							
Receiver	1560-1E-162				2400 GPM		4892

REMARKS:

No. 1 on Gr. Ct. Tank 6' Low
 No. 1 off Gr. Ct. Tank Full
 No. 2 on Gr. Ct. Tank 14' Low
 No. 2 off Gr. Ct. Tank 8' Low

10' below overflow

18' below overflow