


1. SEE S0.01 AND S0.02 FOR GENERAL STRUCTURAL NOTES.
2. SEE S0.02 THROUGH S0.03 FOR TYPICAL STRUCTURAL DETAILS.
3. EXISTING CONDITIONS SHOWN ARE AS TAKEN FROM EXISTING ORIGINAL BUILDING RECORD DRAWINGS DATED MAY 1, 2003 AND MODIFICATION RECORD DRAWINGS DATED MAY 28, 2004. FIELD VERIFY EXISTING CONDITIONS AND NOTIFY THE OWNER'S REPRESENTATIVE AND ENGINEER OF DISCREPANCIES PRIOR TO COMMENCING THE WORK.

1. OUTLINE OF FUTURE 2,000KW GAS GENERATOR ENCLOSURE. COORDINATE GENERATOR FOUNDATION SLAB DIMENSIONS AND KNOCKOUT OPENINGS WITH BASIS OF DESIGN GENERATOR AND ENCLOSURE.
2. NEW 450KW GAS GENERATOR. SEE ELECTRICAL.
3. UNDERGROUND DUCT BANK. SEE ELECTRICAL.
4. SCREENING WALL WITH BRICK FACADE.
5. 16" SQUARE x 0'-6" DEEP SUMP.

[-2'-0"]	INDICATES BOTTOM OF FOOTING, GRADE BEAM, OR SLAB RELATIVE TO EXISTING FINISHED FLOOR ELEVATION $\pm 56.1 \pm$.
<u>SLOPE</u> →	INDICATES SLOPE OF GROUT TOPPING SLAB FROM HIGH TO LOW.
GB-1	INDICATES CONCRETE GRADE BEAM TYPE.



DES: BJK	SCALE: 1/4" = 1'-0"
DRAWN: BJK	HORIZ: N/A
CHECK: BAE	VERT: N/A
DATE: 1/24/20	

FOUNDATION PLAN

DATE	DESCRIPTION	
	DRAWING	SHEET
	S1.01	23