

GENERAL SHEET NOTES



- 1. REFER TO DRAWINGS E0.01 FOR LEGEND AND ABBREVIATIONS AND E0.02 FOR DEFINITIONS AND GENERAL NOTES.
- 2. REFER TO DRAWING E7.01 FOR LIGHTING FIXTURE SCHEDULE AND DRAWING E7.02 FOR PANELBOARD SCHEDULES.
- 3. ALL INTERIOR ELECTRICAL EQUIPMENT SHALL BE IN NEMA 3R ENCLOSURE, UON.
- 4. ALL EXIT AND EMERGENCY LIGHTS SHALL NOT BE SWITCHED OR CONTROLLED BY LIGHTING CONTROL SYSTEM.
- 5. PROVIDE 2#12,1#12AWG GND IN 3/4" GRC TO CIRCUITS INDICATED FOR ALL LIGHTING FIXTURES AND SWITCHES, UON.

SHEET KEYNOTES

- 1 MOUNT LIGHTING FIXTURES SUSPENDED BELOW DUCTWORK. COORDINATE WITH MECHANICAL DRAWINGS.
- 2 RECONNECT LIGHT FIXTURES TO EXISTING BRANCH CIRCUIT.
- 3 EXISTING WALL MOUNTED LIGHTING FIXTURES TO REMAIN.
- 4 PROVIDE INTEGRAL EMERGENCY LIGHTS WITH BATTERY BACKUP (TYP.)

LIGHTING ENLARGED FLOOR PLAN

SCALE: 1/4" = 1'-0"



SCALE: 1/4" = 1'-0"



WESTERN VIRGINIA WATER AUTHORITY  
601 South Jefferson Street, Suite 300  
Roanoke, Virginia 24011

DES:	EJB	SCALE:	1/4" = 1'-0"
DRAWN:	EJB	HORIZ:	N/A
CHECK:	IHK	VERT:	N/A
DATE:	1/24/20		

CRYSTAL SPRING  
PUMP STATION RELOCATION

ELECTRICAL LIGHTING PLAN

DRAWING  
E2.01

SHEET  
58

REV	DATE	DESCRIPTION
1	4/15/20	BUILDING PERMIT REVIEW