



PINE TREE → 33' 12' GATE TO MATCH FENCE

NOTE ②

MOVE 12' GATE IN EXISTING FENCE TO THIS LOCATION.

ALTERATIONS

NOTE ①

228' OF EXISTING FENCE AROUND TANK NO. 1 AND (1) ONE 12' GATE WILL BE REMOVED BY CONTRACTOR AND RE-INSTALLED IN THE PROPOSED FENCE AS SHOWN. (SEE NOTE ②)

PROPOSED 572' FENCE & 12' GATE

250,000 CAP. WATER TANK

TANK NO. 1

BASE OF TANK

EXISTING 228' FENCE & 12' GATE

750,000 CAP. WATER TANK

TANK NO. 2

NOTE ④

ALL CORNERS HAVE BEEN ESTABLISHED.

NOTE ③

LINE POST NOT MORE THAN 10' APART.

WATER DEPARTMENT
CITY OF ROANOKE, VA.
GRANDIN COURT TANKS S.W.
SCALE - 1" = 20'
DRAWN BY - C.G.C DEC. 5, 1966

F-3 D-6