

LOCATION STATESMAN PARK

UNIT NO.	PUMP NO.	PUMP NO.	PUMP NO.
Make	Fairbanks Morse	Allis Chalmers	
G.P.M.	100	200	
Serial No.	K2V1074726	Serial 49837	
Size	1"	3" 5 x 2½D	
Suct. Pres.	0 to 13 PSI	0 to 13 PSI	
Disc. Pres.	72 to 85 PSI	80	
T.D.H.	100 PSI	110 ?	
Storage	2000 gal. Pressure Tank	Pressure Tank	
Make Motor	U.S. Electric	Allis Chalmers	
Serial No.	F9252-00-232	713 N	
H.P.	15	15	
Voltage	230/460	240/480	
Amp. F.L.	38/19	37.4/18.7	
Amp. Fuse	50 AMP.	Breaker	
Phase	3	3	
R.P.M.	3490	3525	
Control	Automatic	Automatic	
In-C Line	Overhead	Overhead	
Elev. Pump			
Max.Elev.Serv.			
Storage Elev.			
Purchased	1973 or 1974	Oct. 1937	

CONTROLS-NAME-KIND-TYPE	SERIAL NO.	VOLTS	AMPS	FUSE	CAP.	PHASE
Clark cat. #A10-42	5732A8	230.460		50		3

REMARKS: