LOCATION STATESMAN PARK

UNIT NO.	PUMP NO.	PUMP NO.	PUMP NO.
Make	Fairbanks Morse	Fairbanks Morse	
G.P.M.	1500	1500	
Serial No.	K2V1074760	K2V1074761	
Size	6"	6"	
Suct. Pres.	0 to 13 PSI	0 to 13 PSI	
Disc. Pres.	100 PSI	100 PSI	
T.D.H.	107 PSI	109.4	
Storage	Suction Storage	Suction Storage	
Make Motor	Fairbanks Morse	Commins Diesel	
Serial No.	503939R7	10381962	
H.P.	125	215 At 2100	
Voltage	230/460		
Amp. F.L.	288/144		
Amp. Fuse	Breaker		
Phase	3		
R.P.M.	1770	Set at 1770	
Control	Automatic	Automatic	
In-C Line	Overhead	Master Fire Pump Controller	
Elev. Pump		Model DCFB-5	
Max.Elev.Serv.		Serial #12330	
Storage Elev.			
Purchased	1974	1974	

CONTROLS-NAME-KIND-TYPE	SERIAL NO.	VOLTS	AMPS	FUSE	CAP.	PHASE	

REMARKS: