

LOCATION NEW HOPE

UNIT NO.	PUMP NO. 1	PUMP NO.	PUMP NO.
Make	Jacuzzi	Jacuzzi	Well Pump
G.P.M.	30 ?	30?	
Serial No.	3D7063908	3D7063910	NO-info.
Size	1 $\frac{1}{4}$ " x 1"	1 $\frac{1}{4}$ " x 1"	
Suct. Pres.	30 Ft. Max.	30 Ft. Max.	Call
Disc. Pres.	40 to 48	40 to 48	Nelson Roanoke
T.D.H.	?	?	
Storage	Penuematic tank	Penuematic	tank
Make Motor	Dayton	Leland faraday	
Serial No.	LR - '15561	AAB1B	
H.P.	2	2	
Voltage	220/440	220/440	
Amp. F.L.	5.4/2.7	6/3	
Amp. Fuse	20 Breaker	20 Breaker	
Phase	3	3	
R.P.M.	3450	3450	
Control	Autocon	Autocon	
In-C Line	Overhead	Overhead	
Elev. Pump			
Max.Elev.Serv.			
Storage Elev.			
Purchased			

[illegible]

REMARKS: