

LOCATION

PEAKWOOD PUMPING STATION
3373 Peakwood Dr., S. W.

UNIT NO.	PUMP NO. 1	PUMP NO. 2	PUMP NO.			
Make	Worthington U 1	Worthington U 1				
G.P.M.	100	100				
Serial No.	1491532	1491531				
Size	2" x 2" 1½	2" x 2" 1½				
Suct. Pres.	32 lbs.	32 lbs.				
Disc. Pres.	145-155 lbs.	155 lbs.				
T.D.H.	300	300				
Storage	Pressure Tank and	Storage Tank				
Make Motor	G.E.	G.E.				
Serial No.	WLO31851	UL261224				
H.P.	15	15				
Voltage	220	220				
Amp. F.L.	38.2	38.2				
Amp. Fuse						
Phase	3	3				
R.P.M.	3530	3530				
Control	Pressure Switch	Pressure Switch				
In-C Line	Underground					
Elev. Pump	1247.01 Floor Level					
Max.Elev.Serv.						
Storage Elev.						
Purchased	1955	1955				
CONTROLS-NAME-KIND-TYPE	SERIAL NO.	VOLTS	AMPS	FUSE	CAP.	PHASE
Chromalox - Heater	UBC751	220				3
Compressor "Quincy"	108-21-2187	220				3
Lights - Switches		110				
Control Switches		110				

REMARKS:

No. 1 on 145 lbs. off 155 lbs. psi
No. 2 on 135 lbs. off 150 lbs. psi

Test Run: May 17-55 Turned on for Reg: Service May 18-55