

*file
copy*

Roanoke, Virginia
August 16, 1976

Honorable Mayor and City Council
Roanoke, Virginia

Dear Members of Council:

Subject: Peakwood Reservoir Change Order No. 1

Hodges Lumber Company, Inc., Roanoke, Virginia, has entered into a contractual agreement with the City of Roanoke for construction of the Peakwood Reservoir.

The original design of the reservoir, and supply piping, was for a double acting altitude valve and one supply and discharge line. Since this particular reservoir would have little to no use with this type connection, Hodges Lumber Company, Inc. was requested to furnish a quotation for a discharge line, which would convert the reservoir to a flow through facility and eliminate the possibility of stagnant water. (The altitude valve is to be furnished by the City of Roanoke.) Hodges Lumber Company, Inc. quotation for the additional work is \$477.00. Funds are available in Account No. A02240191901.

Due to the above addition, and for reasons stated in the enclosed letter, Hodges Lumber Company, Inc. has requested an additional 41 days for completion of the contract from August 5, 1976 to September 15, 1976. The date to receive bids for the piping to connect this reservoir into the City water system is September 3, 1976 with about 41 additional days for construction. The additional time does not effect the operation of the City Water Department.

Therefore, it is recommended that City Council authorize the City Manager to execute Change Order No. 1 to the contract with Hodges Lumber Company, Inc.