



- NOTES:
- 1 FINAL SLOT DIMENSIONS FOR DRIVE MECHANISMS SHALL BE VERIFIED WITH EQUIPMENT MANUFACTURERS CERTIFIED DRAWINGS.
 - 2 HEAT TRACE AND INSULATE EXPOSED SCUM PIPING.

TOP PLAN
1/8"=1'-0"

| | |
|---------------------|--------------|
| DESIGNED | H & S |
| DRAWN | RWB |
| CHECKED | |
| PROJ. ENGR. | DAN |
| APPROVED | |
| NO. | |
| ISSUED FOR | |
| DATE | BY |
| RECORD DRAWINGS | MAR 2008 RLT |
| CONSTRUCTION | MAR 2004 RLT |
| REGULATORY APPROVAL | NOV 2003 RLT |
| PRELIMINARY DESIGN | NOV 2002 RLT |

THIS DOCUMENT ORIGINALLY ISSUED FOR CONSTRUCTION AND SEALED BY ROBERT S. DIFIORE, SEAL NO. 22769

THIS DOCUMENT ORIGINALLY ISSUED FOR CONSTRUCTION AND SEALED BY RONALD L. TAYLOR, SEAL NO. 024649

RECORD DRAWING

THIS DRAWING HAS BEEN MODIFIED TO REFLECT FIELD CHANGES REPORTED BY THE CONTRACTOR OR ANOTHER PARTY, BUT NOT VERIFIED BY THE CERTIFYING ENGINEER. THIS DOCUMENT ORIGINALLY ISSUED AND SEALED BY DAVID A. NAILOR, 025465. THIS MEDIA SHALL NOT BE CONSIDERED A CERTIFIED DOCUMENT.

HAZEN AND SAWYER
Environmental Engineers & Scientists
4011 WestChase Blvd, Raleigh, North Carolina 27607

CITY OF ROANOKE
VIRGINIA

REGIONAL WATER POLLUTION CONTROL PLANT
WET WEATHER IMPROVEMENTS

PRIMARY CLARIFIER NOS 7-9

MECHANICAL

TOP PLAN

| | | |
|---|------------------|-----------|
| THE SCALE BAR SHOWN BELOW MEASURES ONE INCH LONG ON THE ORIGINAL DRAWING. | DATE | JULY 2003 |
| | H & S JOB NUMBER | 30788A |
| | CONTRACT NUMBER | A |
| | DRAWING NUMBER | M261 |