

ROOM FINISH SCHEDULE																		
NO.	DESCRIPTION	FLOOR		BASE		WALL-NORTH		WALL-EAST		WALL-SOUTH		WALL-WEST		CEILING			REMARKS	
		SUBSTRATE	FINISH	SUBSTRATE	FINISH	SUBSTRATE	FINISH	SUBSTRATE	FINISH	SUBSTRATE	FINISH	SUBSTRATE	FINISH	SUBSTRATE	FINISH	HEIGHT		
PRELIMINARY TREATMENT FACILITIES – SEE DRAWINGS A120, A121 & A122																		
120	STAIR 1	CONC	SEALER	CONC/CMU	PT	CONC/CMU	PT	CONC/CMU	PT	CONC/CMU	PT	CONC/CMU	PT	CONC	--	45'-4"		
121	STAIR 2	CONC	SEALER	CONC/CMU	PT	CONC/CMU	PT	CONC/CMU	PT	CONC/CMU	PT	CONC/CMU	PT	CONC	--	45'-4"		
122	GRIT PUMP ROOM	CONC	SEALER	CONC	PT	CONC	PT	CONC	PT	CONC	PT	CONC	PT	CONC	--	VARIES		
123	DUMPSTER ROOM	CONC	SEALER	CONC	PT	CONC	PT	CONC	PT	CONC	PT	CONC	PT	CONC	--	15'-6"	NOTE-2	
124	SCREENING ROOM	CONC	SEALER	CMU	PT	CMU	PT	CONC/CMU	PT	CMU	PT	CMU	PT	CONC	--	21'-4"	NOTE-2	
125	ELECTRICAL ROOM	CONC	SEALER	CMU	PT	CMU	PT	CMU	PT	CMU	PT	CMU	PT	CONC	--	12'-0"		
126	MEZZANINE	CONC/MTL	SEALER	CMU	PT	--	--	CMU	PT	--	--	--	--	CONC	--	16'-10"	NOTE-2	
PRIMARY CLARIFIERS NOS. 7-9 – SEE DRAWINGS A260 & A261																		
260	PUMP ROOM	CONC	SEALER	CONC	PT	CONC	PT	CONC	PT	CONC	PT	CONC	PT	CONC	--	13'-6"		
261	ELECTRICAL ROOM	CONC	SEALER	CMU	PT	CMU	PT	CMU	PT	CMU	PT	CMU	PT	CONC	--	10'-0"		
SCUM CONCENTRATOR BUILDING – SEE DRAWING A290																		
290	SCUM CONCENTRATOR	CONC	SEALER	CMU	PT	CMU	PT	CMU	PT	CMU	PT	CMU	PT	CONC	--	18'-0"		
COAGULATION CHEMICAL FEED FACILITIES – SEE DRAWING A580																		
580	ELECTRICAL ROOM	CONC	SEALER	CMU	PT	CMU	PT	CMU	PT	CMU	PT	CMU	PT	CONC	--	10'-0"		
581	PUMP ROOM	CONC	NOTE-1	CMU	NOTE-1	CMU	PT	CMU	PT	CMU	PT	CMU	PT	CONC	--	10'-0"		
DISINFECTION CHEMICAL FEED FACILITIES – SEE DRAWING A660																		
660	TANK AREA	CONC	NOTE-1	CMU	NOTE-1	CONC/CMU	PT	CONC/CMU	PT	CONC/CMU	PT	CONC/CMU	PT	CONC	--	22'-0"		
661	ELECTRICAL ROOM	CONC	SEALER	CMU	PT	CONC/CMU	PT	CMU	PT	CMU	PT	CMU	PT	CONC	--	22'-0"		
662	TANK AREA	CONC	NOTE-1	CMU	NOTE-1	CONC/CMU	PT	CONC/CMU	PT	CONC/CMU	PT	CONC/CMU	PT	CONC	--	22'-0"		
THICKENED SLUDGE PUMP STATION – SEE DRAWING S720																		
720	PUMP ROOM	CONC	SEALER	CONC	PT	CONC	PT	CONC	PT	CONC	PT	CONC	PT	CONC	--	10'-0"		

- 1 COAT CONCRETE CONTAINMENT WALLS WITH CONTAINMENT LINER. PROVIDE EIGHT INCH HIGH RADIUS COVE AT WALL-FLOOR INTERSECTION.
- 2 PAINT ALL CONCRETE COLUMNS TO MATCH WALLS.

CONC= CONCRETE
CMU= CONCRETE MASONRY UNITS
PT= PAINT
GT= GLAZED TILE
RT= RESILIENT TILE

WINDOW SCHEDULE										
(NO.)	TYPE	MATERIAL	WIDTH	HEIGHT	DETAILS			GLAZING	WINDOW TREATMENT	REMARKS
					HEAD	JAMB	SILL			
PRELIMINARY TREATMENT FACILITIES – SEE DRAWINGS A121 & A122										
U	U	AL	4'-0"	6'-8"	4/A3	4/A3	4/A3	S-1	--	--
V	V	AL	5'-0"	6'-8"	15/A4	15/A4	15/A4	S-1	--	DETAILS– 6/A3, 12/A4, & 17/A4
W	W	AL	6'-0"	6'-8"	16/A4	16/A4	16/A4	S-1	--	DETAILS– 6/A3
GLAZING TYPES										

S-1 INSULATED GLASS- SEE SPECIFICATIONS

Diagram U: A rectangular frame with a width of 4'-0" and a height of 6'-8". The interior is divided into a 2x4 grid of smaller rectangles.

Diagram V: A rectangular frame with a width of 5'-0" and a height of 6'-8". The interior is divided into a 2x4 grid of smaller rectangles.

Diagram W: A rectangular frame with a width of 6'-0" and a height of 6'-8". The interior is divided into a 2x4 grid of smaller rectangles.

1. SEE DISINFECTION CHEMICAL FEED FACILITIES FOR
TRANSLUCENT WALL ASSEMBLIES (SEE DETAIL 65/A662)