

- 1 THE CONTRACTOR SHALL MOUNT ALL TYPE "C" FIXTURES IN THE SCREENINGS AREA AND CLASSIFIER AREA 14' ABOVE FINISHED FLOOR.
- 2 EF-124 MANUAL MOTOR STARTER SHALL BE SUITABLE FOR USE IN A CLASS 1, DIVISION II, GROUP D HAZARDOUS LOCATION.
- 3 ALL LIGHTING FIXTURES SHOWN ON THIS SHEET ARE SUPPLIED FROM LP-13A

