



- NOTES:
- 1 WB INDICATES AL WB&7.02.
 - 2 CONTRACTOR SHALL FIELD VERIFY CHANNEL WIDTH PRIOR TO ORDERING THIS SLIDE GATE.
 - 3 CONTRACTOR SHALL REPLACE EFFLUENT WEIR IN AERATION TANKS 1-6, SEE DETAIL 4/S402
 - 4 CONTRACTOR SHALL ADJUST EXISTING WEIRS IN TANKS 7-16 TO EL 907.00

| | | | |
|-----|---------------------|----------|-----|
| 3 | AS BUILT | OCT 2007 | RLT |
| 2 | CONSTRUCTION | MAR 2004 | RLT |
| 1 | REGULATORY APPROVAL | NOV 2003 | RLT |
| NO. | ISSUED FOR | DATE | BY |

| | |
|-------------|-----|
| DESIGNED | WGL |
| DRAWN | SMH |
| CHECKED | |
| PROJ. ENGR. | DAN |
| APPROVED | |

THIS DOCUMENT ORIGINALLY ISSUED FOR CONSTRUCTION AND SEALED BY ROBERT S. DIFIORE, SEAL NO. 22769

THIS DOCUMENT ORIGINALLY ISSUED FOR CONSTRUCTION AND SEALED BY RONALD L. TAYLOR, SEAL NO. 024649

RECORD DRAWING

THIS DRAWING HAS BEEN MODIFIED TO REFLECT FIELD CHANGES REPORTED BY THE CONTRACTOR OR ANOTHER PARTY, BUT NOT VERIFIED BY THE CERTIFYING ENGINEER. THIS DOCUMENT ORIGINALLY ISSUED AND SEALED BY CHRISTOPHER T. PHILLIPS, 033796. THIS MEDIA SHALL NOT BE CONSIDERED A CERTIFIED DOCUMENT.

HAZEN AND SAWYER
Environmental Engineers & Scientists
4011 WestChase Blvd, Raleigh, North Carolina 27607

CITY OF ROANOKE
VIRGINIA
REGIONAL WATER POLLUTION CONTROL PLANT
PROCESS TRAIN IMPROVEMENTS

AERATION TANK MODIFICATIONS
STRUCTURAL
INTERMEDIATE AND TOP PLANS

| | |
|---------------------------------------------------------------------------|----------------------|
| THE SCALE BAR SHOWN BELOW MEASURES ONE INCH LONG ON THE ORIGINAL DRAWING. | DATE MARCH 2004 |
| H & S JOB NUMBER 30788B | CONTRACT NUMBER B |
| DRAWING NUMBER S401 | |