



- NOTES**
- SEE NOTES ON DRAWING G1.
 - OUTLET PROTECTION SHALL BE 12' LONG x 7' WIDE x 2' THICK CLASS 1 STONE.
 - LEVEL SPREADERS SHALL HAVE DEPTH OF 0.5 FT., WIDTH OF LOWER SIDE SLOPE OF SPREADER OF 6 FT., AND LENGTH OF 10 FT. SPREADER LIP SHALL BE RIGID.
 - APPROXIMATELY 430 SQUARE FEET OF LANDSCAPE PLANTINGS WILL BE PROVIDED UNDER THIS CONTRACT. A SEPARATE LANDSCAPING CONTRACTOR SHALL PERFORM THIS WORK UNDER A BID ALLOWANCE AS DESCRIBED IN THE SPECIFICATIONS.
 - CHANNEL SHALL BE Y-SHAPED AND SHALL BE LINED WITH A TEMPORARY LINING WITH A MINIMUM SHEAR STRESS OF 1.5 LB/SF.



DESIGNED	DAN
DRAWN	RWB
CHECKED	
PROJ. ENGR.	DAN
DATE	APPROVED

RECORD DRAWING

THIS DOCUMENT ORIGINALLY ISSUED FOR CONSTRUCTION AND SEALED BY ROBERT S. DIFIORE, SEAL NO. 22769

THIS DOCUMENT ORIGINALLY ISSUED FOR CONSTRUCTION AND SEALED BY RONALD L. TAYLOR, SEAL NO. 024649

Hazen and Sawyer
Environmental Engineers & Scientists
4011 WestChase Blvd, Raleigh, North Carolina 27607

CITY OF ROANOKE VIRGINIA

**REGIONAL WATER POLLUTION CONTROL PLANT
PROCESS TRAIN IMPROVEMENTS**

**SITE PLAN
GENERAL
PARTIAL SITE PLAN**

THE SCALE BAR SHOWN BELOW MEASURES ONE INCH LONG ON THE ORIGINAL DRAWING.	DATE	JANUARY 2004
	H & S JOB NUMBER	30788C
	CONTRACT NUMBER	C
	DRAWING NUMBER	G10