



- NOTES:
- ALL POTABLE WATER SYSTEM PIPING BELOW SLAB SHALL BE SEAMLESS TYPE "K" COPPER TUBING AND COMPLY WITH ASTM B88-B8A.

				DESIGNED	RDM
				DRAWN	RLG
				CHECKED	RDM
3	RECORD DRAWING	JAN 2006		PROJ. ENGR.	
2	CONSTRUCTION	JAN 2004			
1	REGULATORY APPROVAL	NOV 2003			
NO.	ISSUED FOR	DATE	BY	APPROVED	

RECORD DRAWING

THIS DOCUMENT ORIGINALLY
ISSUED FOR CONSTRUCTION
AND SEALED BY M. GINGER
SCOGGINS, SEAL NUMBER 0402
033234. THIS MEDIA SHALL
NOT BE CONSIDERED A
CERTIFIED DOCUMENT

EDI

Engineered Designs, Inc.
1011 Schaub Dr. Suite 201
Raleigh, North Carolina 27606
Office: 919.851.8481
Fax: 919.851.9703

HAZEN AND SAWYER
Environmental Engineers & Scientists
4011 WestChase Blvd, Raleigh, North Carolina 27607

**CITY OF ROANOKE
VIRGINIA**
**REGIONAL WATER POLLUTION CONTROL PLANT
ADMINISTRATION AND MAINTENANCE BUILDINGS**

**ADMINISTRATION BUILDING
PLUMBING
RISER DIAGRAMS**

THE SCALE BAR SHOWN BELOW MEASURES ONE INCH LONG ON THE ORIGINAL DRAWING.	DATE JANUARY 2004
H & S JOB NUMBER 30788C	CONTRACT NUMBER C
DRAWING NUMBER P923	