



- NOTES**
- 1 REMOVE RECEPTACLES AND ASSOCIATED CONDUIT AND WIRE INSTALLED IN WOODEN TABLE.
 - 2 REMOVE RECEPTACLES, SWITCHES, AND ALL OTHER ELECTRICAL DEVICES IN THE EXISTING UPPER AND LOWER LAB CASEWORK. REMOVE EXISTING HOODS. REMOVE ALL ASSOCIATED CONDUIT AND WIRE.
 - 3 REMOVE LAB FUME HOOD AND EXHAUST EQUIPMENT IN ITS ENTIRETY.
 - 4 THE CONTRACTOR SHALL REMOVE THE EXISTING CONTROL PANELS AND RETURN THEM TO THE OWNER. THE CONTRACTOR SHALL RELOCATE ALL CONTROLS STILL IN USE TO A LOCATION NEAR THE EXISTING CONTROL PANELS. AS A MINIMUM, THE CONTRACTOR SHALL RELOCATE THE FOLLOWING CONTROLS AND EQUIPMENT:
 - ALL FLOW INDICATORS (TEN MINIMUM)
 - ALL VALVE CONTROLLERS (THREE MINIMUM)
 - STANDBY GENERATOR AUNCIATOR PANEL
 - EXISTING PLC
 - SUBMERSIBLE PUMP START/STOP SELECTOR SWITCHESTHE CONTRACTOR SHALL COORDINATE WITH THE OWNER BEFORE THE REMOVAL OR RELOCATION OF ANY INSTRUMENTS AND THE EXISTING CONTROL PANELS. THE CONTRACTOR SHALL RELOCATE ANY OTHER INSTRUMENTS INSTALLED AT THE EXISTING CONTROL PANELS NOT LISTED ABOVE IF REQUESTED BY THE OWNER.
 - 5 THE CONTRACTOR SHALL REMOVE THE EXISTING LIGHT FIXTURES IN THE ROOMS INDICATED ON THIS DRAWING. THE CONTRACTOR SHALL REMOVE THE WIRE AND CONDUIT FROM THE EXISTING LIGHT FIXTURES TO THE EXISTING LIGHTING PANELBOARD.
 - 6 THE EXISTING CIRCUITS FROM THE EXISTING LIGHTING PANELS THAT ARE NOT INDICATED TO BE REMOVED SHALL REMAIN IN SERVICE. CIRCUITS THAT ARE UNUSED AS A RESULT OF THE MODIFICATION INDICATED ON THESE DRAWINGS SHALL BE IDENTIFIED AS "SPARE". THIS IS TYPICAL FOR ALL PANELBOARDS NEAR OR IN THE LAB AREA. THE EXISTING TELEPHONE CONNECTIONS, DATA CONNECTIONS, AND RECEPTACLE CIRCUITS SHALL REMAIN IN OPERATION.

DEMOLITION PLAN
1/4"=1'-0"

				DESIGNED	BRL	RECORD DRAWING	THIS DOCUMENT ORIGINALLY ISSUED FOR CONSTRUCTION AND SEALED BY ROBERT S. DIFIORE, SEAL NO. 22769	THIS DRAWING HAS BEEN MODIFIED TO REFLECT FIELD CHANGES REPORTED BY THE CONTRACTOR OR ANOTHER PARTY, BUT NOT VERIFIED BY THE CERTIFYING ENGINEER. THIS DOCUMENT ORIGINALLY ISSUED AND SEALED BY GERALD J. RATASKY, 026535. THIS MEDIA SHALL NOT BE CONSIDERED A CERTIFIED DOCUMENT.	HAZEN AND SAWYER Environmental Engineers & Scientists 4011 WestChase Blvd, Raleigh, North Carolina 27607	CITY OF ROANOKE VIRGINIA	OPERATIONS/LABORATORY BUILDING MODIFICATIONS	THE SCALE BAR SHOWN BELOW MEASURES ONE INCH LONG ON THE ORIGINAL DRAWING.	DATE JANUARY 2004	
				DRAWN	DJG								H & S JOB NUMBER 30788C	
				CHECKED									CONTRACT NUMBER C	DRAWING NUMBER E900
3	RECORD DRAWING	JAN 2006	RLT	PROJ. ENGR.	DAN	APPROVED	THIS DOCUMENT ORIGINALLY ISSUED FOR CONSTRUCTION AND SEALED BY RONALD L. TAYLOR, SEAL NO. 024649			REGIONAL WATER POLLUTION CONTROL PLANT PROCESS TRAIN IMPROVEMENTS	ELECTRICAL DEMOLITION PLAN			
2	CONSTRUCTION	JAN 2004	RLT											
1	REGULATORY APPROVAL	NOV 2003	RLT											
NO.	ISSUED FOR	DATE	BY											

POST DATE 01/11/06 8:15am FILE# H:\30788\30788C\ELEC\BROOK by HBAATCHELLOR XREF# 30788C\mbe\30788B, 900\B-a-pl.