



3 THE UPS RECEPTACLE SHALL BE A 30A, 250VAC, 2-POLE, 3 WIRE, WITH ISOLATED GROUND. THE UPS RECEPTACLE SHALL BE HUBBELL CAT NUMBER IG2620A OR EQUAL

				DESIGNED	BRL
				DRAWN	DJG
				CHECKED	
3	RECORD DRAWING	JAN 2006	RLT	PROJ. ENGR.	DAN
2	CONSTRUCTION	JAN 2004	RLT		
1	REGULATORY APPROVAL	NOV 2003	RLT		
NO.	ISSUED FOR	DATE	BY	APPROVED	

\_\_\_\_\_

APPROVED

THIS DOCUMENT ORIGINALLY ISSUED  
FOR CONSTRUCTION AND SEALED BY  
RONALD L. TAYLOR, SEAL NO. 024649

THIS DRAWING HAS BEEN MODIFIED TO REFLECT FIELD  
CHANGES REPORTED BY THE CONTRACTOR OR ANOTHER  
PARTY, BUT NOT VERIFIED BY THE CERTIFYING ENGINEER.  
THIS DOCUMENT ORIGINALLY ISSUED AND SEALED BY  
GERALD J. RATASKY, 026535. THIS MEDIA SHALL NOT  
BE CONSIDERED A CERTIFIED DOCUMENT.

**HAZEN AND SAWYER**  
Environmental Engineers & Scientists  
4011 WestChase Blvd, Raleigh, North Carolina 27607

CITY OF ROANOKE  
VIRGINIA

---

REGIONAL WATER POLLUTION CONTROL PLANT  
PROCESS TRAIN IMPROVEMENTS

ADMINISTRATION BUILDING  
ELECTRICAL  
BOTTOM POWER PLAN

THE SCALE BAR SHOWN BELOW MEASURES ONE INCH LONG ON THE ORIGINAL DRAWING.	DATE JANUARY 2004	
	H & S JOB NUMBER 30788C	
	CONTRACT NUMBER C	DRAWING NUMBER E922